Republic of the Philippines
DEPARTMENT OF HEALTH
Regional Health Office XI
SOUTHERN PHILIPPINES MEDICAL CENTER
REGIONAL PUBLIC HEALTH LABORATORY
J.P. Laurel Avenue, Bajada, Davao City
Tel. no, (082) 2272731 loc. 5095

SPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMC PMCSPMCSPMCSPMCSPMCSPMC

Laboratory No. B-0336-2019

Date and time of Collection :	4:30 AM	Feb. 4, 2019
Receipt :	9:54 AM	Feb. 4, 2019
Examination *from*	1:00 PM	Feb. 4, 2019
to		Feb. 11,2019

Submitted by:

Name : WILFREDO G. SANCHEZ
Address : LIANGA WATER DISTRICT
ANNEX – A, MARKET MALL , LIANGA ,
SURIGAO DEL SUR

Source : Developed spring
Treatment Done : Chlorination
Description : Clear Drinking Water [X] Yes [ ] No
Sampling Point : Sample 1 : Faucet of RICHEL PILAPIL, located at Zone 9 Purok 1
Barangay Wakat, Barobo, Surigao del Sur

Remarks :

BACTERIOLOGICAL EXAMINATION OF WATER

Method- MTFT	Result of Analysis	Remarks
Total Coliforms	<1.1 MPN/100mL	PASSED
Fecal Coliforms	<1.1 MPN/100mL	
Standard Plate Count	<1.0 CFU/mL	

Limits	*Public Water Supplies*
MPN/100ml. Total Coliforms	*Less than 1 (<1.1) or 0*
MPN/100ml. Fecal Coliforms	*Less than 1 (<1.1) or 0*
CFU/ml. Standard Plate Count	*Less than 500*

Note: Results of examination are specifically related to samples as received. This report shall not be reproduced, except in full, without the approval of RPHL – SPMC and is not valid for purposes of advertising or sales promotion.

RPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRP

Analyst:
Josephine R. Vergara
Medical Technologist II

Certified correct:
Maria Erlinda G. Dayoan
Chemist III

Noted by:
Marlon M. Maramion, M.D.,FPSP
Pathologist

Republic of the Philippines
DEPARTMENT OF HEALTH
Regional Health Office XI
SOUTHERN PHILIPPINES MEDICAL CENTER
REGIONAL PUBLIC HEALTH LABORATORY
J.P. Laurel Avenue, Bajada, Davao City
Tel. no, (082) 2272731 loc. 5095

SPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMC

Laboratory No. B-0337-2019

Date and time of Collection :	4:40 AM	Feb. 4, 2019
Receipt :	9:54 AM	Feb. 4, 2019
Examination *from*	1:00 PM	Feb. 4, 2019
to		Feb. 11,2019

Submitted by:

Name : WILFREDO G. SANCHEZ
Address : LIANGA WATER DISTRICT
ANNEX – A, MARKET MALL , LIANGA ,
SURIGAO DEL SUR

Source : Developed spring
Treatment Done : Chlorination
Description : Clear Drinking Water [X] Yes [ ] No
Sampling Point : Sample 2 : Faucet of ANGELITO CONSIGNA, located at Zone 8
Purok 2 Barangay Liatimco, Lianga Surigao del Sur

Remarks :

BACTERIOLOGICAL EXAMINATION OF WATER

Method- MTFT	Result of Analysis	Remarks
Total Coliforms	<1.1 MPN/100mL	PASSED
Fecal Coliforms	<1.1 MPN/100mL	
Standard Plate Count	<1.0 CFU/mL	

Limits	*Public Water Supplies*
MPN/100ml. Total Coliforms	*Less than 1 (<1.1) or 0*
MPN/100ml. Fecal Coliforms	*Less than 1 (<1.1) or 0*
CFU/ml. Standard Plate Count	*Less than 500*

Note: Results of examination are specifically related to samples as received. This report shall not be reproduced, except in full, without the approval of RPHL – SPMC and is not valid for purposes of advertising or sales promotion.

RPHLRPHLRPHLR

Republic of the Philippines
DEPARTMENT OF HEALTH
Regional Health Office XI
SOUTHERN PHILIPPINES MEDICAL CENTER
REGIONAL PUBLIC HEALTH LABORATORY
J.P. Laurel Avenue, Bajada, Davao City
Tel. no, (082) 2272731 loc. 5095

SPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMC

Laboratory No. B-0338-2019

Date and time of Collection :	4:48 AM	Feb. 4, 2019
Receipt :	9:54 AM	Feb. 4, 2019
Examination *from*	1:00 PM	Feb. 4, 2019
to		Feb, 11,2019

Submitted by:

Name : WILFREDO G. SANCHEZ

Address : LIANGA WATER DISTRICT
ANNEX – A, MARKET MALL , LIANGA ,
SURIGAO DEL SUR

Source : Developed spring

Treatment Done : Chlorination

Description : Clear Drinking Water [X] Yes [ ] No

Sampling Point : Sample 3 : Faucet of MANUEL SABATIN JR., located at Zone 1
Purok 1 Lianga Surigao del Sur

Remarks :

BACTERIOLOGICAL EXAMINATION OF WATER

Method- MTFT	Result of Analysis	Remarks
Total Coliforms	<1.1 MPN/100mL	PASSED
Fecal Coliforms	<1.1 MPN/100mL	
Standard Plate Count	<1.0 CFU/mL	

Limits	*Public Water Supplies*
MPN/100ml. Total Coliforms	*Less than 1 (<1.1) or 0*
MPN/100ml. Fecal Coliforms	*Less than 1 (<1.1) or 0*
CFU/ml. Standard Plate Count	*Less than 500*

Note: Results of examination are specifically related to samples as received. This report shall not be reproduced, except in full, without the approval of RPHL – SPMC and is not valid for purposes of advertising or sales promotion.

RPHLRPHLRPHLR

Republic of the Philippines
DEPARTMENT OF HEALTH
Regional Health Office XI
SOUTHERN PHILIPPINES MEDICAL CENTER
REGIONAL PUBLIC HEALTH LABORATORY
J.P. Laurel Avenue, Bajada, Davao City
Tel. no, (082) 2272731 loc. 5095

SPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMC

Laboratory No. B-0339-2019

Date and time of Collection :	4:55 AM	Feb. 4, 2019
Receipt :	9:54 AM	Feb. 4, 2019
Examination *from*	1:00 PM	Feb. 4, 2019
to		Feb. 11,2019

Submitted by:

Name : WILFREDO G. SANCHEZ
Address : LIANGA WATER DISTRICT
ANNEX – A, MARKET MALL , LIANGA ,
SURIGAO DEL SUR

Source : Developed spring
Treatment Done : Chlorination
Description : Clear Drinking Water [X] Yes [ ] No
Sampling Point : Sample 4 : Faucet of MARILYN CALABRIA, located at Zone 6
Purok 7, Causeway Diatagon, Lianga Surigao del Sur

Remarks :

BACTERIOLOGICAL EXAMINATION OF WATER

Method- MTFT	Result of Analysis	Remarks
Total Coliforms	<1.1 MPN/100mL	PASSED
Fecal Coliforms	<1.1 MPN/100mL	
Standard Plate Count	15 CFU/mL	

Limits	*Public Water Supplies*
MPN/100ml. Total Coliforms	*Less than 1 (<1.1) or 0*
MPN/100ml. Fecal Coliforms	*Less than 1 (<1.1) or 0*
CFU/ml. Standard Plate Count	*Less than 500*

Note: Results of examination are specifically related to samples as received. This report shall not be reproduced, except in full, without the approval of RPHL – SPMC and is not valid for purposes of advertising or sales promotion.

RPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRP

Analyst:
Josephine R. Vergara
Medical Technologist II

Certified correct:
Maria Erlinda G. Dayoan
Chemist III

Noted by:
Marlon M. Maramion, M.D.,FPSP
Pathologist

Republic of the Philippines
DEPARTMENT OF HEALTH
Regional Health Office XI
SOUTHERN PHILIPPINES MEDICAL CENTER
REGIONAL PUBLIC HEALTH LABORATORY
J.P. Laurel Avenue, Bajada, Davao City
Tel. no, (082) 2272731 loc. 5095

SPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMCSPMC PMCSPMCSPMCSPMCSPMCSPMC

Laboratory No. B-0340-2019

Date and time of Collection :	5:00 AM	Feb. 4, 2019
Receipt :	9:54 AM	Feb. 4, 2019
Examination *from*	1:00 PM	Feb. 4, 2019
to		Feb. 11,2019

Submitted by:

Name : WILFREDO G. SANCHEZ

Address : LIANGA WATER DISTRICT
ANNEX – A, MARKET MALL , LIANGA ,
SURIGAO DEL SUR

Source : Developed spring

Treatment Done : Chlorination

Description : Clear Drinking Water [X] Yes [ ] No

Sampling Point : Sample 5 : Faucet of ROBERTO GALAGAR, located at Zone 5
Purok 4, Diatagon, Lianga Surigao del Sur

Remarks :

BACTERIOLOGICAL EXAMINATION OF WATER

Method- MTFT	Result of Analysis	Remarks
Total Coliforms	<1.1 MPN/100mL	PASSED
Fecal Coliforms	<1.1 MPN/100mL	
Standard Plate Count	<1.0 CFU/mL	

Limits	*Public Water Supplies*
MPN/100ml. Total Coliforms	*Less than 1 (<1.1) or 0*
MPN/100ml. Fecal Coliforms	*Less than 1 (<1.1) or 0*
CFU/ml. Standard Plate Count	*Less than 500*

Note: Results of examination are specifically related to samples as received. This report shall not be reproduced, except in full, without the approval of RPHL – SPMC and is not valid for purposes of advertising or sales promotion.

RPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRPHLRP

Analyst:
Josephine R. Vergara
Medical Technologist II

Certified correct:
Maria Erlinda G. Dayoan
Chemist III

Noted by:
Marlon M. Maramion, M.D.,FPSP
Pathologist